

## WATER WELL DRILLING CONTRACTOR/PUMP INSTALLER ADMINISTRATIVE ENFORCEMENT ACTIONS

Below is a listing of recent administrative enforcement actions initiated by the Michigan Department of Environment, Great Lakes, and Energy to revoke or suspend a water well drilling contractor or pump installer certificate of registration. The actions are authorized under Part 127, Water Supply and Sewer Systems, of the Public Health Code, 1978 PA 368, as amended, and the associated administrative rules (Michigan Water Well Construction and Pump Installation Code).

Name/Business	Registration Number	Alleged Type of Violation	Outcome
<p>Marty Griffore Bacon Well Drilling 8865 Roberts Road Mancelona, Michigan 49659</p>	<p>05-2453</p>	<p>MCL 333.12707 Failure to submit complete and accurate water well records within 60 days. MCL 333.12709 Failure to respond to order letter. R325.1612 Failure to plug abandoned wells.</p>	<p>Notice of Suspension: December 18, 2017</p> <p>Notice of Revocation: January 26, 2018</p>
<p>Richard Layman Pure Water Well 6429 M-65 South Lachine, Michigan 49753</p>	<p>04-1920</p>	<p>R325.1621 Failure to construct a well that is adequate in size, design, and development for the intended use. R325.1638 Failure to confine the flow within the well casing. R325.1663 Failure to stop the flow from an abandoned well. R325.1638 Failure to provide backflow prevention. R325.1675 Failure to provide an accurate well record. MCL333.12709 Failure to respond to order letters.</p>	<p>Request for Contested Case Hearing: 5/30/2019</p>
<p>Mr. Matthew F. Vergari Scott's Well Service 623 East Eddy School Road Mancelona, Michigan 49659</p>	<p>40-2524</p>	<p>MCL 333.12707 Failure to submit complete and accurate water well records within 60 days. R 325.1632 Failure to install minimum 25 feet of casing. R 325.1639 Failure to provide a sand-free well MCL 333.12709 Failure to comply with order letters.</p>	<p>Request for Contested Case Hearing: 6/25/2021</p> <p>Consent Agreement: 8/25/2021 \$10,000 penalty</p>